

## October 4, 2004

U.S. Nuclear Regulatory Commission Attention: Document Control Desk

11555 Rockville Pike

Rockville, Maryland 20852

Serial No.: 04-555 NL&OS/PRW Rev 1

Docket Nos.: 50-338/339

50-280/281 50-336/423

License Nos.: NPF-4/7

DPR-32/37 DPR-65 NPF-49

VIRGINIA ELECTRIC AND POWER COMPANY (DOMINION)

DOMINION NUCLEAR CONNECTICUT, INC. (DNC)

NORTH ANNA POWER STATION UNITS 1 AND 2

SURRY POWER STATION UNITS 1 AND 2

MILLSTONE POWER STATION UNITS 2 AND 3

SUPPLEMENT TO SIXTY DAY RESPONSE TO NRC BULLETIN 2004-01

INSPECTION OF ALLOY 82/182/600 MATERIALS USED IN THE

FABRICATION OF PRESSURIZER PENETRATIONS AND STEAM SPACE

PIPING CONNECTIONS AT PRESSURIZED WATER REACTORS

In a letter dated May 28, 2004 the NRC issued NRC Bulletin 2004-01, "Inspection of Alloy 82/182/600 Materials Used in the Fabrication of Pressurizer Penetrations and Steam Space Piping Connections at Pressurized-Water Reactors [PWRs]." The bulletin requested information related to the materials from which pressurizer penetrations and steam space piping connections were fabricated. It also requested information related to the inspections that have been and will be performed to ensure degradation of Alloy 82/182/600 materials used in the fabrication of pressurizer penetrations and steam space piping connections will be identified, adequately characterized and repaired. In a letter dated July 27, 2004 (Serial No. 04-331) Dominion and DNC provided the requested response for Millstone Power Station Units 2 and 3, North Anna Power Station Units 1 and 2, and for Surry Power Station Units 1 and 2.

In a letter dated September 3, 2004, the NRC requested additional information regarding the July 27, 2004 submittal for North Anna Power Station Units 1 and 2. Of specific concern was the intention to ensure "...that an appropriate dialogue would be established with the NRC staff in the event that circumferential primary water stress corrosion cracking (PWSCC) is identified at any locations under the scope of NRC Bulletin 2004-01."

In response to the NRC's request, Dominion/DNC makes the following commitment for Millstone Power Station Units 2 and 3 and North Anna Power Station Units 1 and 2:

"If circumferential primary water stress corrosion cracking is observed in either the pressure boundary or non-pressure boundary portions of any locations covered under the scope of NRC Bulletin 2004-01, Dominion/DNC will develop plans to perform an extent-of-condition evaluation and discuss those plans with the NRC staff prior to restarting the affected unit."

As previously stated in Dominion's July 27, 2004 submittal, Surry Unit 1 and Unit 2 pressurizers consist of stainless steel clad carbon steel vessels with stainless steel penetrations and stainless steel nozzle welds and have no Alloy 82/182/600 components or welds. Accordingly, there are no welds covered under the scope of NRC Bulletin 2004-01 at Surry Power Station.

If you have any questions or require additional information, please contact Mr. Paul R. Willoughby at (804) 273-3572.

Very truly yours,

Leslie N. Hartz

Vice President - Nuclear Engineering

Commitments made in this letter: One, as noted above

cc U.S. Nuclear Regulatory Commission Region I 475 Allendale Road King of Prussia, PA 19406-1415

> U.S. Nuclear Regulatory Commission Region II Sam Nunn Atlanta Federal Center 61 Forsyth Street, SW Suite 23 T85 Atlanta, Georgia 30303-8931

Mr. N. P. Garrett NRC Senior Resident Inspector Surry Power Station

Mr. M. T. Widmann NRC Senior Resident Inspector North Anna Power Station

Mr. S. M. Schneider NRC Senior Resident Inspector Millstone Power Station

Mr. S. R. Monarque NRC Project Manager North Anna Power Station, Surry Power Station

Mr. V. Nerses NRC Senior Project Manager Millstone Power Station Units 2&3

Mr. J. E. Reasor, Jr.
Old Dominion Electric Cooperative
Innsbrook Corporate Center, Suite 300
4201 Dominion Blvd.
Glen Allen, Virginia 23060

Serial No. 04-555 Response to Request for Additional Information Page 4 of 4

COMMONWEALTH OF VIRGINIA	)

The foregoing document was acknowledged before me, in and for the County and Commonwealth aforesaid, today by Leslie N. Hartz, who is Vice President - Nuclear Engineering of Virginia Electric & Power Company and Dominion Nuclear Connecticut, Inc. She has affirmed before me that she is duly authorized to execute and file the foregoing document in behalf of that company, and that the statements in the document are true to the best of her knowledge and belief.

My Commission Expires: May 31, 2006.

Motary Public

(SEAL)